QC ABSTRACT

Nameof Work: "Restoration of BWSSB Cutting portion in LBS Nagara Census Block No 130/1, 130/2& 131/2 in Yelahanka new Town ward No 04", BBMP, Bangalore.

SI. No.	Item	Quantity As Per BOQ	Required No's of testes as per Frequency	Actual No's of testes as per Frequency	Tests Result
1	1:3:6	137.92 Cum	1	1	Pass
2	M30	261.21 Cum	9	9	Pass
3	WMM	98.53 Cum	-	-	Pass
		Gradation	1	1	Pass
		AIV	1	1	Pass
		Shape Test	1	1	Pass
		Atterberg Limits	1	1	Pass

Cubes	0-5 Cum	1Set
	6-15 Cum	2Set
	16-30 Cum	3Set
	31-50 Cum	4Set
	Add 1set for extra 50Cum	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಯಲಹಂಕ ಉಪನಗರ ಉಪವಿಭಾಗ.
ಜಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-೧೦೯

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory